



# CSIR-INSTITUTE OF MINERALS & MATERIALS TECHNOLOGY.

(A Govt. of India Autonomous Body)  
Environmental Chemical Laboratory  
Bhubaneswar, Odisha  
TEST REPORT



Issued to : National Institute of Science Education & Research, Bhubaneswar	Date : 31.01.2025
Test report No –2025/NABL/ECL/001	
Source of Sample : Rushikulya Hostel, NISER	Sample receiving Date : 13.01.2025
Type of Sample : Drinking Water	Sample Analysis Date : 13.01.2025

Sl No	Characteristics	Test Method (P) of IS:3025	Requirements as per IS 10500:2012(Latest Version)		Test Result
			Acceptable limit	Permissible Limit	
1.	Turbidity, NTU	Part 10	1	5	0.40
2.	pH@Temp° C	Part 11	6.5-8.5	No relaxation	8.04@25.0
3.	Total Dissolved Solids mg/L	Part 16	500	2000	151.0
4.	Total Hardness (as CaCO <sub>3</sub> ),mg/L	Part 21	200	600	80.0
5.	Calcium as Ca, mg/L	Part 40	75	200	23.25
6.	Magnesium as Mg, mg/L	Part 46	30	100	5.35
7.	Alkalinity as CaCO <sub>3</sub> , mg/L	Part 23	200	600	78.0
8.	Chloride as Cl, mg/L	Part 32	250	1000	15.0
9.	Sulfate as SO <sub>4</sub> , mg/L	Part 24	200	400	5.12
10.	Fluoride as F, mg/L	Part 60	1.0	1.5	0.14
11.	Iron as Fe, mg/L	Part 53	0.3	No relaxation	0.356
12.	Copper as Cu, mg/L	Part 42	0.05	1.5	0.033
13.	Manganese as Mn, mg/L	APHA(PART 3111B)	0.1	0.3	<0.002
14.	Zinc as Zn, mg/L	Part 49	5.0	15.0	0.123
15.	Lead as Pb, mg/L	Part 47	0.01	No relaxation	0.018
16.	Cadmium as Cd, mg/L	Part 41	0.003	No relaxation	<0.003
17.	Chromium as Cr, mg/L	Part 52	0.05	No relaxation	<0.005
18.	Nickel as Ni, mg/l	Part 54	0.02	No relaxation	0.016

Authorized Signatory

**Dr. Arakshita Majhi**

Senior Principal Scientist

(Environmental Chemical Lab) (ISO17025:2017, NABL Lab)

Environmental & Sustainability Dept.

CSIR-Institute of Minerals & Materials Technology

Bhubaneswar-751013, Odisha, INDIA

Senior Principal Scientist

Phone : 0674-2379236,

E mail - arakshita@immt.res.in

### NOTES :

1. The sample is drawn by the client & result relates to the sample tested.
2. This certificate shall not be reproduced wholly or in part without prior written consent of the laboratory.
3. This certificate shall not be used in any advertising media or as evidence in the court of Law without prior written consent of laboratory.
4. Latest version of test methods used as per latest specification.
5. It is recommended that the acceptable limit is to be implemented. Values in excess of those mentioned in "acceptable limit" render the water not suitable, but still may be tolerated in the absence of an alternative source but up to the limits indicate under "permissible limit" in the absence of alternative sources, above which the source will have to be rejected.

Non NABL Test report – P.T.O

'End of Test Report'





# CSIR-INSTITUTE OF MINERALS & MATERIALS TECHNOLOGY.

(A Govt. of India Autonomous Body)  
Environmental Chemical Laboratory

Bhubaneswar, Odisha  
TEST REPORT

Issued to : National Institute of Science Education &  
Research, Bhubaneswar

Date : 31.01.2025

Test report No -2025/NABL/ECL/001

Source of Sample : Rushikulya Hostel, NISER

Sample receiving Date : 13.01.2025

Type of Sample : Drinking Water

Sample Analysis Date : 13.01.2025

Sl No	Characteristics	Test Method (P) of IS:3025	Requirements as per IS 10500:2012(Latest Version)		Test Result
			Acceptable limit	Permissible Limit	
19.	*Color, Hazen units	Part 4	5	15	<5
20.	*Odour	Part 5	Agreeable	Agreeable	Agreeable
21.	*Conductivity, $\mu\text{s}/\text{cm}$	Part 14	-	-	212
22.	*Total Suspended Solid, mg/l	Part 17	-	-	6.0
23.	*Nitrite as $\text{NO}_2$ , mg/L	Part 34	-	-	0.079
24.	*Nitrate as $\text{NO}_3$ , mg/L	Part 34	45	No relaxation	3.42
25.	Sodium, mg/l	Part 45	-	-	10.75
26.	Potassium, mg/l	Part 45	-	-	0.91
27.	Residual Free Chlorine, mg/l	Part 26	0.2	1.0	<0.01
28.	Arsenic as As, mg/l	Part 37	0.01	No relaxation	<0.001
29.	Dissolved Oxygen, mg/l	Part 38	-	-	6.80
30.	Biological Oxygen Demand, mg/l	Part 44	-	-	0.10
31.	Chemical Oxygen Demand, mg/l	Part 58	-	-	<1.0
32.	Oil and Grease, mg/l	Part 39	0.5	No relaxation	<0.5

Authorized Signatory

**Dr. Arakshita Majhi**

Senior Principal Scientist

Senior Principal Scientist (Chemical Lab) (ISO17025:2017, NABL Lab)

Environmental & Sustainability Dept.

CSIR-Institute of Minerals & Materials Technology

Bhubaneswar-751013, Odisha, INDIA

E mail - arakshita@immt.res.in

#### NOTES :

1. The sample is drawn by the client & result relates to the sample tested.
2. This certificate shall not be reproduced wholly or in part without prior written consent of the laboratory.
3. This certificate shall not be used in any advertising media or as evidence in the court of Law without prior written consent of laboratory.
4. Latest version of test methods used as per latest specification.
5. It is recommended that the acceptable limit is to be implemented. Values in excess of those mentioned in "acceptable limit" render the water not suitable, but still may be tolerated in the absence of an alternative source but up to the limits indicate under "permissible limit" in the absence of alternative sources, above which the source will have to be rejected.
6. Testing parameters which are not set limitation has marked as "-".

'End of Test Report'